

## Gordon Yates

---

**From:** Gordon Yates  
**Sent:** Wednesday, March 20, 2024 1:40 PM  
**To:** water-enforcement-report@adeq.state.ar.us; Allen-Daniel, Leslie  
**Cc:** Monty Ledbetter; Harold Mauldin  
**Subject:** Blending Valve 3/20/24 still open

On Friday, March 15<sup>th</sup>, 2024 Davidson Wastewater Treatment Plant ( Permit Number: AR0033880) began blending Flow at Primary Effluent. Since that time, approximately 16 MGD has gone through blending and into cloth filtration And UV disinfection. We are still experiencing high flows and the blending valve remains open. I will follow up with Total blending flow volume when we are able to close the blending valve.

Thank you,

Gordon Yates  
Plant Supervisor  
City of Hot Springs  
501-276-2314