



**James B Sorrells**  
**Operations Manager**

## **Non Compliance Report**

**Arkansas Department of Environmental Quality**  
**NPDES Enforcement Section**  
**5301 Northshore Drive**  
**NLR. AR 72118**

**NPDES Permit No. AR0033880 - Discharge Number 001**

---

**City of Hot Springs Wastewater Treatment**  
**320 Davidson Dr**  
**Hot Springs Ar 71901**

**Date of Violations: 3-11-2016/3-13-2016**

        **Other: Bypass of Secondary Treatment**

**Reason for the violation:** I & I in collection system, heavy rainfall more than treatment could withstand. Causing upset conditions inside the plant and partial bypass of secondary treatment

**Duration of the violation: 3-11-2016/3-13-2016**

**Corrective action taken:** Ongoing I & I rehab

**Expected Date of Compliance is:** Compliance resumed upon influent flows returning to normal.

\

**Signature of Cognizant or Ranking Official** \_\_\_\_\_

A handwritten signature in black ink, appearing to be "JBS", is written over a horizontal line.

## James Sorrells

---

**From:** Stephen Youngblood <Stephen.Youngblood@arkansas.gov>  
**Sent:** Monday, March 14, 2016 8:48 AM  
**To:** James Sorrells; allen-daniel@adeq.state.ar.us  
**Cc:** Monty Ledbetter; Bill Burrough  
**Subject:** RE: Hot springs WWTP

James,

Thanks for the notification.

It would help the 3 systems within Arkansas which Ouachita River raw water intakes downstream for their WWTP if you have a secondary bypass in the future so that they can better prepared. They are;

Kimzey Regional Water District  
Keith Daniell  
(870) 245-6053  
[mkdaniell@hotmail.com](mailto:mkdaniell@hotmail.com)

Malvern Waterworks  
David Coston,  
(501) 332-3634  
[dcoston@malvernar.gov](mailto:dcoston@malvernar.gov)

Arkadelphia Waterworks  
Brenda Gills  
(870) 246-5863  
[bcgills@cityofarkadelphia.com](mailto:bcgills@cityofarkadelphia.com)

Regards,

Stephen Youngblood, P.E.

-----Original Message-----

**From:** James Sorrells [<mailto:JSorrells@cityhs.net>]  
**Sent:** Friday, March 11, 2016 7:08 PM  
**To:** allen-daniel@adeq.state.ar.us; Stephen Youngblood  
**Cc:** Monty Ledbetter; Bill Burrough  
**Subject:** Hot springs WWTP

Due to excessive high flows the Regional wastewater plant went on secondary treatment bypass then continued into disinfection before discharge undetermined at this time how long it will last.

Sent from my iPhone