

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's

I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?

Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125

Cell 501 627-2022

jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's

I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?


Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125

Cell 501 627-2022

jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's

I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?

Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125

Cell 501 627-2022

jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's
I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?


Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125

Cell 501 627-2022

jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's

I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?

Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125

Cell 501 627-2022

jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's

I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?


Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125

Cell 501 627-2022

jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's
I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?

Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125
Cell 501 627-2022
jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's

I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?


Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125

Cell 501 627-2022

jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's

I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?

Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125

Cell 501 627-2022

jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's
I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?


Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125

Cell 501 627-2022

jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's
I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?

Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125

Cell 501 627-2022

jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's
I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?


Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125

Cell 501 627-2022

jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's

I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?

Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125

Cell 501 627-2022

jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: TX1-Q

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Third Quarter Bio-Monitoring testing

I am including this letter and am asking that it not be a non compliance along with the extra lab reports with the third quarter DMR's

I would ask that the laboratory error Ceriodaphnia dubia test and the resample to be discarded. See explanation below.

We fill this problem was due to:

Laboratory error (technician Dropped tray of Daphnia). We made arrangements with Laboratory manager, and that they would start test over with second renewal sample and we would collect and send another sample (4th) to complete the test

We received word the next week that the lab technician had failed to start the test over, and now all the samples had exceeded holding time.

In our haste to clean everything in time to get another sample before the quarter ended. This is not how we normally operate and collect our regular samples. That next sample failed.

We plan on correcting the problem in this manner:

We ran extra test on the failed samples TOC Aluminum and sulfates. That showed nothing everything looked good. We started a retest with the same water that failed a few days earlier, and the daphnia survived fine.

Time estimated that it will take to correct problem:

Right now I am looking at whether we stirred something up in our hurry to clean up. Could it be not enough chlorine causing some sort of bacteria, or too much chlorine causing a problem at times?


Should you need anything else, or this is not enough information please contact me.

Work 501 262-1125

Cell 501 627-2022

jsorrells@cityhs.net

Sincerely,
James B Sorrells


Authorized Signature

10-21-2013
Date