


Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: Hot Springs Wastewater NPDES Permit No.: AR0033880 Monitoring Period (Month/Year) January / 2015

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions				
Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location	
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/Environmental Impact		CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots/Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action(s) Taken to Address SSO	Discharge Location
Catherine Heights Rd.	MH# 1750	01/02/2015	01/03/2015	90000	R	NEAH	EC	CR--Gulpha
Carpenter Dam Rd.	MH# 5259	01/03/2015	01/03/2015	35000	R	NEAH	HC & EC	CR--Unknown
McLeod St.	MH# 991	01/03/2015	01/03/2015	15000	R	NEAH	EC	CR--Stokes
McLeod St.	MH# 998	01/03/2015	01/03/2015	30000	R	NEAH	EC	CR--Stokes
Carpenter Dam Rd.	MH# 5259	01/08/2015	01/08/2015	7000	PF	NEAH	HC & EC	CR--Unknown
Carpenter Dam Rd.	MH# 5259	01/21/2015	01/21/2015	500	PF	NEAH	EC	CR--Unknown
857 Carpenter Dam Rd.	MH# 5259	01/30/2015	01/30/2015	4,500	E	NEAH	EC	CR--Unknown


 Signature of Cognizant or Ranking Official

2-12-2015
 Date


I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment of knowing violations.

City of Ho
Wastewa
320 Davidson Drive
Hot Springs, AR 71901

OF THE RETURN ADDRESS, FOLD AT BOTTOM LINE
CERTIFIED MAIL™



7011 2970 0004 3941 3135



U.S. POSTAGE
PAID
HOT SPRINGS, AR
71913
FEB 13, 15
AMOUNT

\$7 40
00078670-08

1000

72118

Ar Department of Environmental
Quality
5301 North Shore Drive
North Little Rock, AR 72118-5317
DmRS