

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034347 Discharge Number: 001-A

Facility: CITY OF SHERIDAN -- WWTP

Address: P.O. BOX 486 / GATZKE DRIVE

City: SHERIDAN State: AR Zip: 72150

Contact: DENNIS ROGERS Phone: 870-942-2722

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
02/28/2018	D.O INST MIN		6.88	7

We feel this problem was due to:

the extreme flooding. The creek level was up to very near the weir of the discharge structure. This did not allow the effluent to cascade down. Therefore the effluent could not aerate when taking the sample

We plan on correcting the problem in this manner:

there should not be another problem. The creek level is seldom that high

Time estimated that it will take to correct problem:

Next sample

Sincerely,

Dennis Rogers
Authorized Signature

3-23-18
Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)