

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0034347 Discharge Number: 001-A

Facility: CITY OF SHERIDAN -- WWTP

Address: P.O. BOX 486 / GATZKE DRIVE

City: SHERIDAN State: AR Zip: 72150

Contact: ~~DENNIS ROGERS~~ DAVID Fitzgerald Phone: 870-942-2722

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>6-20-2022</u>	<u>% of Stream Flow</u>		<u>100% of Stream Flow</u>	<u>20% Stream Flow</u>
<u>6-20-2022</u>	<u>Minimum Flow</u>		<u>0-Flow in creek</u>	<u>6.5 MGD Min.</u>

We feel this problem was due to:

Valve wrench broke that operates the gravity flow valve into holding pond. We had to lower holding pond to get to the valve and close it.

We plan on correcting the problem in this manner:

The universal joint in the valve wrench broke, replaced it with a stainless steel universal joint and it is installed. Called ADEQ on 6-20-22 to report what we had to do to fix the problem.

Time estimated that it will take to correct problem:

We lowered pond enough in 2 days to fix the wrench and the wrench is now 100% stainless steel.

Sincerely,


 Authorized Signature

7-18-2022
 Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)