

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034347 Discharge Number: 001-A  
Facility: CITY OF SHERIDAN -- WWTP  
Address: P.O. BOX 486 / GATZKE DRIVE  
City: SHERIDAN State: AR Zip: 72150  
Contact: DENNIS ROGERS Phone: 870-942-2722

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
05/31/2019	F.C 30 DA GEO		230	200
05/31/2019	F.C 7 DA GEO		1400	400
05/31/2019	PH MAX		10.10	10

We feel this problem was due to:

Excessive rain and a heavy Flow through the lagoons  
may have caused the high fecal counts

The algae bloom probably caused the high PH

We plan on correcting the problem in this manner:

Flows have slowed down

Maybe algae bloom has lessened

Time estimated that it will take to correct problem:

My fecal count on 6-4-19 was < 2

My fecal count on 6-7-19 was 2

Both of my PH measurements was less than 10

Sincerely,

Dennis Rogers

Authorized Signature

6-25-19

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)