

## NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 NPDES Enforcement Section  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0034347 Discharge Number: 001-A

Facility: CITY OF SHERIDAN -- WWTP

Address: P.O. BOX 486 / GATZKE DRIVE

City: SHERIDAN State: AR Zip: 72150

Contact: DAVID Fitzgerald Phone: 870-942-2722

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading AVG,	Quality or Concentration Max	Permit Limits
11-16-2022	Minimum upstream	3.16 MGD	5.86 MGD	6.5 MGD
11-17-2022	Flow before	4.55 MGD	5.24 MGD	6.5 MGD
11-18-2022	discharging 6.5 MGD	2.36 MGD	4.15 MGD	

We feel this problem was due to:

No Rainfall since June of 2022. 5 months no discharge  
Had less than 12" of Freeboard on Holding Pond levee. Called and  
reported we needed to discharge @ 9:05 AM 11-16-2022

We plan on correcting the problem in this manner:

All samples were taken and all within limits

Time estimated that it will take to correct problem:

2021 we had 4 months with no rain 2022 we had 5 months with  
no rain.

Sincerely,

  
 Authorized Signature

12-6-2022  
 Date

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)