

SHERIDAN WATER AND SEWER  
P O BOX 486  
SHERIDAN, AR 72150

TO: Allen Anderson

FROM: DAVID Fitzgerald

PHONE:

PHONE: 870-942-2722

FAX: 501-682-0880

FAX: 870-942-1937


- Urgent
- 
- For Review
- 
- Please Comment
- 
- Please Reply

Date sent: 9-17-15

Time sent:

Number of pages including cover page:

MESSAGE:



SAMPLE NON-COMPLIANCE REPORT

Permit Number: AR0034347

Facility Name: City of Sheridan (Sheridan Water Works)

Month/Year: June 2015

Authorized Signature/Date: [Signature] 9-17-15

Type of Violation (Avg/Max, Bypass Overflow, Etc.)	Permit Limit	Date of Violation	Duration of Viol.	Cause of Violation	Corrective Action or Other Narrative
6.5 Min STREAM Flow	6.5	6-6-15	No more than a	Sensor may have had a logor debris	Start using 3 Flow reading & AVG them
6.3 MGD	6.5	6-6-15	Hour	Pass in front of it that blocked beam going to the other bank of the creek.	to get a true stream flow and not just 1 low reading that is not representative of the true stream flow.
<p>I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may includes fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)</p>					