

SAMPLE NON-COMPLIANCE REPORT

Permit Number: AR0034347

Facility Name: City of Sheridan (Sheridan Water Works)

Month/Year: March 2016

Authorized Signature/Date: Don Fitzgerald 6-22-16

Type of Violation (Avg/Max,, Bypass Overflow, Etc.)	Permit Limit	Date of Violation	Duration of Viol.	Cause of Violation	Corrective Action or Other Narrative
10.6 P.H.	10.0	3-22-16	1 Day	Shallow Depth in Holding Pond Alga Bloom	Hold till Pond got more depth.
OverFlow		3-11-16	8 hrs	7 1/2 inches of Rain in 3 days	N/A- Everything in town was under water 3 to 4 feet.
<p>I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may includes fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)</p>				<p><i>Don Fitzgerald</i></p>	


City of Sheridan

WATER AND SEWER WORKS

101 WEST HIGH STREET
P.O. BOX 486
SHERIDAN, ARKANSAS 72150

LITTLE ROCK AR 722

22 JUN 2016 PM 3 L



ADEQ
NPDES Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118-5317

72118-531799

