

SAMPLE NON-COMPLIANCE REPORT

Permit Number: AR0034347

Facility Name: City of Sheridan (Sheridan Water Works)

Month/Year: May 2015

Authorized Signature/Date: Dan Fitzgerald 6-22-15

Type of Violation (Avg/Max., Bypass Overflow, Etc.)	Permit Limit	Date of Violation	Duration of Viol.	Cause of Violation	Corrective Action or Other Narrative
STREAM flow MINIMUM	6.5 Min	5-4, 5-6 5-7	3-Days	The floods left our Creek Monitor under silt and it could not read the creek Flow.	Creek Monitor was pulled up and cleaned and silt removed around it and it seems to be reading right.
<p>I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and a maximum imprisonment of between 6 months and 5 years.)</p>					

City of Sheridan

WATER AND SEWER WORKS

101 WEST HIGH STREET
P.O. BOX 486
SHERIDAN, ARKANSAS 72150

LITTLE ROCK AR 722

23 JUN 2015 PM 4 L



ADEQ Enforcemnet Branch
5301 Northshore Drive
No Little Rock, AR 72118-5317

72118531799

