



November 2, 2021

Christina McCutcheon
Enforcement Coordinator, Office of Water Quality
Arkansas Energy and Environment
Division of Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118

RE: Third Quarter 2021 Progress Report – Stuttgart Wastewater Treatment Facility
NPDES Permit #AR0034380

Ms. McCutcheon:

This letter serves as the 2021 Third Quarter Progress Report for the City of Stuttgart wastewater treatment facility. PMI has been tasked by the city to develop corrective action measures in response to CAO LIS 21-035. The Corrective Action Plan has been submitted to DEQ by the deadline established in the CAO.

Measures taken at the treatment facility include converting disinfection to PAA to eliminate total residual chlorine violations. Sludge in the equalization basin is being removed when flows allow to eliminate TSS violations. Per the CAO, influent samples have been completed to monitor alkalinity and other parameters that affect the biological processes within the treatment plant. PMI is continuing to work with Stuttgart to develop long-term solutions to gain compliance with effluent limits.

Please contact me at 501-221-7122 or bwingfield@pmico.com with any questions or comments concerning this report.

Sincerely,

PMI

Brad Wingfield, P.E.
Principal – Engineering Division