



MEETING ATTENDANCE

Name	Organization	Job Title	E-Mail Address	Telephone Number
Stacie Wassell	DEQ	Deputy Associate Director	wassell@adeq.state.ar.us	501-682-0886
Richard Healey	DEQ	Enforcement Branch Manager	healey@adeq.state.ar.us	501-682-0640
Leslie Allen-Daniel	DEQ	Enforcement Coordinator	ALLEN-DANIEL@adeq.state.ar.us	501-682-0615
Christina McCutcheon	DEQ	Enforcement Analyst	christina.mccutcheon@adeq.state.ar.us	501-682-0840
Alan York	DEQ	Associate Director	alan.york@adeq.state.ar.us	501-683-6372
Aaron Baggett	DEQ	Inspector	aaron.baggett@adeq.state.ar.us	501-683-6267
Bryan Leamons, P.E.	DEQ	Senior Operations Manager	jessica.sears@adeq.state.ar.us	501-682-0621
Dr. Zachary Carroll, P.E.	DEQ	Engineer	zachary.carroll@adeq.state.ar.us	501-682-0625
Honorable Norma K. Stabala	Stuttgart	Mayor	clerk1@cebridge.net	870-673-3535
Tommy Lawson	Stuttgart	Water Superintendent - Class III WW	stuttgartwater@centurytel.net	870-673-3246
Brad Wingfield, P.E.	PMI	Engineer	bwingfield@pmico.com	
Danny Wilson	Stuttgart	Class III WW Operator		870-674-4819
Eddy Carlock	Stuttgart	Class III WW Operator		
Kenneth Terry	Stuttgart	Assistant Water Manager – Class III WW		
Dan Stewart	Stuttgart	Office Manager		
Becky Burgess	Stuttgart	City Clerk	clerk1@cebridge.net	

REMARKS: Meeting was held via ZOOM.

AGENDA

DEQ meeting with City of Stuttgart

AR0034860

Thursday, March 10, 2022 at 9:30am

1. Introductions
2. Discuss Unsatisfactory Inspection
 - a. Repeat Violations
 - b. Corrective Actions Taken
 - i. New valves – extra on order
 - ii. Trickling filters operating
 - iii. Draining pond to repair
 1. 2 week process
 - iv. Belt press operational
 - c. Denali – sonar drone for solids volume
3. CAO Drafting
 - a. Address staffing storage for proper management
4. Discussed Solutions
 - a. Mayor applying for funding
 - b. Digester drain not operable
 - i. Waiting on pump
5. Deliverables
 - a. Submit photographs of completed Corrective Actions
 - b. Revised CAP with Milestone Schedule