

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034380 Discharge Number: 001-A
Facility: CITY OF STUTT GART
Address: 612 SOUTH COLLEGE ST.
City: STUTT GART State: AR Zip: 72160
Contact: TOMMY LAWSON, OPERATOR Phone: 870-673-3246

| Date of Non-Compliance | Parameter Exceeded | Quantity or Loading | Quality or Concentration | Permit Limits |
|------------------------|--------------------|---------------------|--------------------------|---------------|
| 01/31/2022 | CBOD MO AVG | | 12.23 | 10 |
| 01/31/2022 | CBOD 7 DA AVG | | 16.84 | 15 |
| | | | | |
| | | | | |

We feel this problem was due to:

Trickling Filters being down

We plan on correcting the problem in this manner:

Replacing Pump assembly for Filter Recirculation and Repair on Plant Influent pump station

Time estimated that it will take to correct problem:

This time Next Month or Before depending on weather conditions

Sincerely,

Authorized Signature

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)