

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0034380 Discharge Number: 001-A
 Facility: CITY OF STUTT GART
 Address: 612 SOUTH COLLEGE ST.
 City: STUTT GART State: AR Zip: 72160
 Contact: TOMMY LAWSON, OPERATOR Phone: 870-673-3246

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
06/30/2022	TSS MO AVG	552.36	40.32	437.9/15
06/30/2022	TSS 7 DA AVG		90.0	22.5
06/30/2022	F.C 7 DA GEO		>2420	2000
06/30/2022	CBOD MO AVG		10.36	10

We feel this problem was due to:

Bod exceeded limit due to accumulation of screenings in center well. TSS is High due to sludge Build up in disinfection chamber.

We plan on correcting the problem in this manner:

Removing screenings from center well. Sludge removal is ongoing and prices have been obtained for removal of sludge.

Time estimated that it will take to correct problem:

Screenings Removal is complete. Capital improvements are being evaluated to correct problems and funding sources are being sought.

Sincerely,


 Authorized Signature

 Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)