

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034380 Discharge Number: 001-A
Facility: CITY OF STUTTGART
Address: 612 SOUTH COLLEGE ST.
City: STUTTGART State: AR Zip: 72160
Contact: TOMMY LAWSON, OPERATOR Phone: 870-673-3246

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
06/30/2022	TSS MO AVG	552.36	40.32	437.9/15
06/30/2022	TSS 7 DA AVG		90.0	22.5
06/30/2022	F.C 7 DA GEO		>2420	2000
06/30/2022	CBOD MO AVG		10.36	10

We feel this problem was due to:

~~BOD is high due to trickling filter pump being down. TSS is over permit limits due to excessive sludge in the EQ Basin and disinfection chamber. Fecal is high from sludge in disinfection chamber causing issues with PAA oxidation.~~

We plan on correcting the problem in this manner:

~~Sludge removal is ongoing and prices have been obtained for removal of sludge from EQ Basin and disinfection chamber. Trickling filters are in the process of getting back to normal.~~

Time estimated that it will take to correct problem:

~~DEQ is in receipt of a milestone schedule contained within a corrective action plan. Capital improvements are being evaluated to correct the problems and funding sources are being sought.~~

Sincerely,



Submitted By:

Date

7-25-2022

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)