

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034380 Discharge Number: 001-A
Facility: CITY OF STUTTGART
Address: 612 SOUTH COLLEGE ST.
City: STUTTGART State: AR Zip: 72160
Contact: TOMMY LAWSON, OPERATOR Phone: 870-673-3246

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
05/31/2022	TSS MO AVG		16.12	15
05/31/2022	TSS 7 DA AVG		22.53	22.5
05/31/2022	F.C 30 DA GEO		1315	1000
05/31/2022	F.C 7 DA GEO		2271	2000

We feel this problem was due to:

TSS is over permit due to excessive sludge in the EQ Basin and Chlorine Contact Basin. F.C. is over permit due to excessive sludge in the Chlorine Contact Basin.

We plan on correcting the problem in this manner:

Sludge removal is scheduled when Vac Truck is available

Time estimated that it will take to correct problem:

Capital improvements are being looked at to correct the problems and funding sources are being sought.

Sincerely,

Authorized Signature

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)