NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality NPDES Enforcement Section 5301 Northshore Drive North Little Rock, AR 72118

RE: NPDES Per	mit No: AR0034	380 Discharg	ge Number: A - 001	
Facility: CITY O	F STUTTGART			
Address: 612 SC	OUTH COLLEGE	ST.		
City: STUTTGART		State:	AR	Zip : 72160
Contact: TOMMY	LAWSON, OPERA	TOR Phone:	870-673-3246	
Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
November-23	Fecal 7 D GEO		2420 #/100mL	2000 #/100mL
				· · · · · · · · · · · · · · · · · · ·
We feel this probler TRC is high from slud		ntact basin.		
We plan on correction				
Time estimated that Capitol improvements			estimated time of sludge removal	will begin by March 2023.
Sincerely, OWYMA Authorized Signature	I AWSEN		12 -19-2024 Date	

<u>Certification Statement</u>: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)