

NON-COMPLIANCE LETTER

DATE: November 21, 2016

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY  
5301 NORTH SHORE DRIVE  
NORTH LITTLE ROCK, AR 72118-5317  
ATTN: ENFORCEMENT SECTION

RE: NPDES PERMIT NO: AR0034380

DISCHARGE NUMBER:001-A

CLIENT: STUTTGART, CITY OF  
ADDRESS:P.O. BOX 130  
CITY: STUTTGART  
STATE: AR  
ZIP: 72160  
PHONE:  
CONTACT: TOMMY LAWSON, MANAGER

DATE OF NON-COMPLIANCE	PARAMETER EXCEEDED	CONCENTRATION	LOADING	PERMIT LIMITS
10/01-31/16	D.O INST MIN	5.90		6
	TSS MO AVG	16.25		15
	TSS 7 DA AVG	28.30		22.5
	F.C 30DA GEO	2054		1000
	F.C 7 DA GEO	10046		2000

WE FEEL THIS PROBLEM WAS DUE TO:

Vacuum Regulator Failure - F.C.      Blower Failure - D.O.  
Decant down for repairs - TSS


WE PLAN ON CORRECTING THE PROBLEM IN THIS MANNER:

Overhaul Vacuum Regulator - F.C.      Change Our Fuses - D.O.  
Replating Gearbox on Decant - TSS

TIME ESTIMATED THAT IT WILL TAKE:

Vacuum Regulator is repaired - F.C.      Blower has been repaired - D.O.  
Gearbox repaired within 2 months - TSS

YOURS TRULY,

  
\_\_\_\_\_  
AUTHORIZED SIGNATURE

STUTT GART MUNICIPAL WATER WORKS  
P.O. BOX 130  
STUTT GART, AR 72160  
PHONE: 870-673-3246

LITTLE ROCK  
AR 722  
21 NOV '16  
PM 2 L

Hasler  
11/21/2016  
FIRST-CLASS MAIL  
**US POSTAGE** \$000.67<sup>5</sup>



ZIP 72160  
011E10672532

Arkansas Department of Environmental Quality  
Enforcement Section  
5301 North Shore Drive  
North Little Rock, AR 72118-5317

72118-531799

