

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034380 Discharge Number: 001-A
Facility: CITY OF STUTTGART
Address: 612 SOUTH COLLEGE ST.
City: STUTTGART State: AR Zip: 72160
Contact: TOMMY LAWSON, OPERATOR Phone: 870-673-3246

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
07/31/2021	TRC - INST MAX		0.31	<0.011
07/31/2021	F.C 7 DA GEO		2151	2000

We feel this problem was due to: we are
In the process of Finding the correct Pump
setting to achieve the correct
Dosage of Parasitic Acid to stay within
limit on Permit.

We plan on correcting the problem in this manner:
Increase chemical dosage and lower Demand

Time estimated that it will take to correct problem:
3 weeks

Sincerely,

Authorized Signature Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)