

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034380 Discharge Number: 001-A

Facility: CITY OF STUTTGART

Address: 612 SOUTH COLLEGE ST.

City: STUTTGART State: AR Zip: 72160

Contact: TOMMY LAWSON, OPERATOR Phone: 870-673-3246

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
06/30/2021	TRC - INST MAX		0.29	<0.011

We feel this problem was due to:

Sampling during the start-up of new chemical equipment

We plan on correcting the problem in this manner:

Getting the correct dosages of the Acid that will take the place of  $\text{CH}_4 + \text{SO}_2$ .

Time estimated that it will take to correct problem:

3 weeks

Sincerely,

Tommy Lawson  
Authorized Signature

7/27/2021  
Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)