

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0034380 Discharge Number: 001-A
 Facility: CITY OF STUTTGART
 Address: 612 SOUTH COLLEGE ST.
 City: STUTTGART State: AR Zip: 72160
 Contact: TOMMY LAWSON, OPERATOR Phone: 870-673-3246

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
04/30/2022	CBOD MO AVG		10.16	10
04/30/2022	TSS 7 DA AVG		22.54	22.5

We feel this problem was due to:

Bod is high due to Trickling Pump being down
TSS is over permit due to excessive sludge in the
EQ Basin and Chlorine Contact Basin

We plan on correcting the problem in this manner:

Trickling filter is back up and running. Sludge
removal is on going. Estimates have been
obtained for Sludge Removal from EQ Basin

Time estimated that it will take to correct problem:

Capital improvements are being looked at to
correct the problems and funding sources
are being sought

Sincerely,

Tommy Lawson
 Authorized Signature

6-1-2022
 Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)