

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034380 Discharge Number: 001-A
Facility: CITY OF STUTTGART
Address: 612 SOUTH COLLEGE ST.
City: STUTTGART State: AR Zip: 72160
Contact: TOMMY LAWSON, OPERATOR Phone: 870-673-3246

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
08/31/2022	TSS MO AVG	1711.28	152.96	437.9/15
08/31/2022	TSS 7 DA AVG		314.0	22.5
08/31/2022	CBOD MO AVG		11.31	10
08/31/2022	CBOD 7 DA AVG		16.37	15

We feel this problem was due to:

TSS is over permit limits due to excessive
sludge in FQ Basin. Trickling filter down,

We plan on correcting the problem in this manner:

Sludge removal is ongoing and prices have been
obtained for removal of sludge from FQ Basin.
Re Repairing distribution arm on trickling
filters

Time estimated that it will take to correct problem:

DLO is in receipt of a milestone schedule contained
within a corrective plan. Improvements to the
plant are being evaluated to correct the problems.

Sincerely,

Tommy Lawson

Authorized Signature

9-30-2022

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)