

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0034380 **Discharge Number: A - 001**

Facility: CITY OF STUTT GART

Address: 612 SOUTH COLLEGE ST.

City: STUTT GART **State:** AR **Zip:** 72160

Contact: TOMMY LAWSON, OPERATOR **Phone:** 870-673-3246

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
December-23	CBOD MO AVG		15.89mg/L	10.0mg/L
December-23	CBOD 7D AVG		16.67mg/L	15.0mg/L

We feel this problem was due to:
 CBOD is above limit from the Trickling filter recirculation pump being down during monitoring period.

We plan on correcting the problem in this manner:
 Repairing the recirculation pump

Time estimated that it will take to correct the problem/s:
 Pump is back on line.

Sincerely,

Tommy Lawson
 Authorized Signature

2-6-2024
 Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)