

NON-COMPLIANCE REPORT

**Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118**

RE: NPDES Permit No: AR0034380 Discharge Number: A - 001

Facility: CITY OF STUTTGART

Address: 612 SOUTH COLLEGE ST.

City: STUTTGART State: AR Zip: 72160

Contact: TOMMY LAWSON, OPERATOR Phone: 870-673-3246

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
February-24	CBOD MO AVG		13.6mg/L	10mg/L
February-24	CBOD 7D AVG		19.0mg/L	15.0mg/L
February-24	Fecal 7 D GEO		1287 #/100mL	1000 #/100mL
February-24	Fecal 30 D GEO		20000 #/100mL	2000 #/100mL
February-24	TSS MO AVG		15.7mg/L	15.0mg/L
February-24	TSS 7 D AVG		52.0mg/L	22.5mg/L

We feel this problem was due to:

CBOD Rag build up in center column

Fecal We were troubleshooting the PAA pumps

We plan on correcting the problem in this manner:

CBOD Remove rags from center column.

Fecal Flushing out discharge line.


Time estimated that it will take to correct the problem/s:

CBOD 4 hrs.

Fecal 3 hrs,

Sincerely,


 Authorized Signature


 Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)