

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0034380 Discharge Number: A - 001

Facility: CITY OF STUTT GART

Address: 612 SOUTH COLLEGE ST.

City: STUTT GART

State: AR

Zip: 72160

Contact: TOMMY LAWSON, OPERATOR

Phone: 870-673-3246

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
May-23	D. O.		5.57mg/L (Inst. Min)	6.0mg/L (Inst. Min)
May-23	Ammonia		2.2mg/L Mo Avg & 6.08mg/L 7 D Avg	2.1mg/L Mo Avg & 5.2mg/L 7 D Avg
May-23	Fecal 7 D GEO		2420 #/100mL	2000 #/100mL

We feel this problem was due to:

*DO - Blowers being Down for Replacement
 Ammonia - Thrust Bearing on Trickling Filter
 Fecal - PAA treatment failure.*

We plan on correcting the problem in this manner:

*DO - By Changing out Blowers
 Ammonia - Keep it Lubricated till it is Demolished
 Fecal - Repairing Leak*

Time estimated that it will take to correct the problem/s:

*DO - 6 to 8 Weeks
 Ammonia - Lubrication is ongoing
 Fecal - 2 days*

Sincerely,

Tommy Lawson
 Authorized Signature

6-30-2023
 Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)