

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034380

Discharge Number: 001-A-Monthly

Facility: Stuttgart, City of

Address: 1011 West 10th Street

City: Stuttgart

State: AR

Zip: 72160

Contact: Danny Wilson

Phone: 870-673-3246

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
November, 2022	TSS		45.0 mg/l 7day Avg	22.5 mg/l 7 day Avg limit
November, 2022	TRC		0.64 mg/l	0.011 mg/l Inst. Max limit
November, 2022	CBOD		65.0 mg/l	15.0 mg/l 7dat Avg limit

We feel this problem was due to:

TSS is over permit limit due to excessive Sludge in EQ Basin and Sludge Press down for repairs.

TRC is high from excessive sludge in disinfection chamber.

CBOD is high to excessive carry over of screenings from bar rake restricting discharge openings.

We plan on correcting the problem in this manner:


Sludge removal prices have been obtained.

Trickling filter arms are cleaned daily.

Time estimated that it will take to correct the problem/s:

DEQ have been sent a milestone schedule with a corrective action plan. Capitol improvements are being evaluated to correct all exsisting problems at the present time.

Sincerely,



Authorized Signature

12/28/2022

Date