

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0034380

Discharge Number: 001-A-Monthly

Facility: Stuttgart, City of

Address: 1011 West 10th Street

City: Stuttgart

State: AR

Zip: 72160

Contact: Danny Wilson

Phone: 870-673-3246

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
October, 2022	TSS	604.96 lb/d Mo. Avg	106 mg/l 7day Avg	437.9 lb/d Mo.Avg & 22.5 mg/l 7 day Avg limit
October, 2022	TRC		0.9 mg/l	0.011 mg/l Inst. Max limit
October, 2022	CBOD		34.8 mg/l	15.0 mg/l 7dat Avg limit

We feel this problem was due to:

TSS is over permit limits due to excessive sludge in BQ Basin and disinfection chamber. TRC is high from sludge in disinfection chamber causing issues with PAA oxidation. CBOD is high due to trickling filters arms being plugged.

We plan on correcting the problem in this manner:

sludge removal is ongoing and prices have been obtained for removal of sludge. Trickling filters are in the process of being maintained.

Time estimated that it will take to correct the problem/s:

Deq is in receipt of a milestone schedule contained within a corrective action plan. Capital improvements are being evaluated to correct the problems and funding sources are being

Sincerely,

sought.

Jemmy Lawson  
Authorized Signature

12-1-2022  
Date