

NON-COMPLIANCE LETTER

DATE: 1-31-2014

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
5301 NORTH SHORE DRIVE
NORTH LITTLE ROCK, AR 72118-5317
ATTN: ENFORCEMENT SECTION

RE: NPDES PERMIT NO: AR0034380 DISCHARGE NUMBER 001-A

CLIENT: STUTTGART, CITY OF.
ADDRESS: P.O. BOX 130
CITY: STUTTGART
STATE: AR
ZIP: 72160
PHONE:
CONTACT: TOMMY LAWSON

DATE OF NON-COMPLIANCE	PARAMETER EXCEEDED	CONCENTRATION	LOADING	PERMIT LIMITS
12/01-31/13	CBOD 7 DA AVG	16.330		15

WE FEEL THIS PROBLEM WAS DUE TO:
Fluctuating flow through the wastewater plant due to contractors installing new bar rake

WE PLAN ON CORRECTING THE PROBLEM IN THIS MANNER:

Completion of bar rake installation should correct this problem

TIME ESTIMATED THAT IT WILL TAKE:

2 weeks is the estimated time of completion

YOURS TRULY,

Tommy Lawson
AUTHORIZED SIGNATURE

Sanitary Sewer Overflow (SSO) Monthly Report with DMR

Mail to: ADEQ, Water Division 1503 Northshore Drive North Little Rock, AR 72118 Mail NO later than the 25th of the month following the monitoring period. You should send in the same envelope with the monthly DMR.

Facility Name: Stuttgart Municipal WWTP

NPDES Permit No. AR 0034380

Monitoring Period(Month/Year): 12 / 2013

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions				
Cause(s) of SSO		SSO Impact	Action(s) Taken	Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental Impact		CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots / Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		PN-Public Notification	PA-Paved Area
				CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Jimmie Gibson

Signature of Cognizant or Ranking Official

Manager

TITLE

1-31-14

Date

STUTT GART MUNICIPAL WATER WORKS

612 SOUTH COLLEGE - P.O. BOX 130
STUTT GART, ARKANSAS 72160-0130

Hasler

FIRST-CLASS MAIL

01/31/2014

US POSTAGE

\$00.90⁰



ZIP 72160
011D10608725

ENFORCEMENT SECTION
AR DEPARTMENT OF ENVIRONMENTAL QUAL
5301 NORTH SHORE DRIVE
NORTH LITTLE ROCK, AR 72118-5317

721185317 R015

