

NON-COMPLIANCE LETTER

DATE: January 25, 2017

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
5301 NORTH SHORE DRIVE
NORTH LITTLE ROCK, AR 72118-5317
ATTN: ENFORCEMENT SECTION

RE: NPDES PERMIT NO: AR0034380

DISCHARGE NUMBER:001-A

CLIENT: STUTTGART, CITY OF
ADDRESS:P.O. BOX 130
CITY: STUTTGART
STATE: AR
ZIP: 72160
PHONE:
CONTACT: TOMMY LAWSON, MANAGER

DATE OF NON-COMPLIANCE	PARAMETER EXCEEDED	CONCENTRATION	LOADING	PERMIT LIMITS
12/01-31/16	F.C 30DA GEO	2471		1000
	F.C 7 DA GEO	21638		2000

WE FEEL THIS PROBLEM WAS DUE TO:

Feeder line to rotometer leaking

WE PLAN ON CORRECTING THE PROBLEM IN THIS MANNER:

Temporarily repaired; waiting on new feeder line replacement

TIME ESTIMATED THAT IT WILL TAKE:

30 min. repair time

YOURS TRULY,



AUTHORIZED SIGNATURE

STUTT GART MUNICIPAL WATER WORKS
P.O. Box 130
STUTT GART, AR 72160
PHONE: 870-673-3246

LITTLE ROCK
AR 722
02 FEB 17
PM 4L

Hasler FIRST-CLASS MAIL
02/01/2017
US POSTAGE \$000.88⁰



ZIP 72160
01E10672532

Arkansas Dept. of Environmental Quality
5301 North Shore Drive
N. L. R. AR 72118-5317

72118-531799

