

NON-COMPLIANCE LETTER

DATE: March 25, 2015

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
5301 NORTH SHORE DRIVE
NORTH LITTLE ROCK, AR 72118-5317
ATTN: ENFORCEMENT SECTION

RE: NPDES PERMIT NO: AR0034380

DISCHARGE NUMBER 001-A

CLIENT: STUTTGART, CITY OF.
ADDRESS: P.O. BOX 130
CITY: STUTTGART
STATE: AR
ZIP: 72160
PHONE:
CONTACT: TOMMY LAWSON

DATE OF NON-COMPLIANCE	PARAMETER EXCEEDED	CONCENTRATION	LOADING	PERMIT LIMITS
02/01-28/15	TRC INST MAX	<.050		.033

WE FEEL THIS PROBLEM WAS DUE TO:

The compression fitting on vacuum (SO2) regulator split causing a vacuum leak

WE PLAN ON CORRECTING THE PROBLEM IN THIS MANNER:

This part has been replaced and is regulating correctly.

TIME ESTIMATED THAT IT WILL TAKE:

This problem was corrected within a two hour period

YOURS TRULY,



AUTHORIZED SIGNATURE

STUTT GART MUNICIPAL WATER WORKS

612 SOUTH COLLEGE - P.O. BOX 130
STUTT GART, ARKANSAS 72160-0130

RETURN SERVICE REQUESTED

Arkansas Dept. of Environmental Quality
Water Division
5301 Northshore Drive
North Little Rock AR 72118-5317

Hasler

03/30/2015

US POSTAGE

FIRST-CLASS MAIL

\$00.48⁰



ZIP 72160
011D10608725

72118531799

