

NON-COMPLIANCE LETTER

DATE: August 15, 2016

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY  
5301 NORTH SHORE DRIVE  
NORTH LITTLE ROCK, AR 72118-5317  
ATTN: ENFORCEMENT SECTION

RE: NPDES PERMIT NO: AR0034380

DISCHARGE NUMBER:001-A

CLIENT: STUTTGART, CITY OF  
ADDRESS:P.O. BOX 130  
CITY: STUTTGART  
STATE: AR  
ZIP: 72160  
PHONE:  
CONTACT: TOMMY LAWSON, MANAGER

DATE OF NON-COMPLIANCE	PARAMETER EXCEEDED	CONCENTRATION	LOADING	PERMIT LIMITS
07/01-31/16	F.C 7DA GEO	2879		2000

WE FEEL THIS PROBLEM WAS DUE TO:

A metal gasket that failed on the regulator feed line

WE PLAN ON CORRECTING THE PROBLEM IN THIS MANNER:

The gasket has been replaced and is back in operation

TIME ESTIMATED THAT IT WILL TAKE:

The gasket was replaced in 30 min.

YOURS TRULY,

*Tommy Lawson*  
AUTHORIZED SIGNATURE

STUTT GART MUNICIPAL WATER WORKS  
P.O. BOX 130  
STUTT GART, AR 72160  
PHONE: 870-673-3246

LITTLE ROCK  
AR 722  
16 AUG 16  
FR 42

Hasler

FIRST-CLASS MAIL

08/16/2016

**US POSTAGE** \$000.67<sup>5</sup>



ZIP 72160  
011E10672532

Arkansas Department of Environmental Quality  
Enforcement Section  
5301 North Shore Drive  
North Little Rock, AR 72118-5317

72118-531799

