

NON-COMPLIANCE LETTER

DATE: April 24, 2015

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY  
5301 NORTH SHORE DRIVE  
NORTH LITTLE ROCK, AR 72118-5317  
ATTN: ENFORCEMENT SECTION

RE: NPDES PERMIT NO: AR0034380

DISCHARGE NUMBER 001-A

CLIENT: STUTTGART, CITY OF.  
ADDRESS: P.O. BOX 130  
CITY: STUTTGART  
STATE: AR  
ZIP: 72160  
PHONE:  
CONTACT: TOMMY LAWSON

DATE OF NON-COMPLIANCE	PARAMETER EXCEEDED	CONCENTRATION	LOADING	PERMIT LIMITS
03/01-31/15	TRC INST MAX	<.050		.033

WE FEEL THIS PROBLEM WAS DUE TO:  
Rotometer failure on SO2 Feeder


WE PLAN ON CORRECTING THE PROBLEM IN THIS MANNER:

Cleaned Rotometer of debris

TIME ESTIMATED THAT IT WILL TAKE:

Problem has been corrected

YOURS TRULY,

  
\_\_\_\_\_  
AUTHORIZED SIGNATURE

STUTT GART MUNICIPAL WATER WORKS  
P.O. BOX 130  
STUTT GART, AR 72160  
PHONE: 870-673-3246

Hasler

04/24/2015

US POSTAGE

FIRST-CLASS MAIL

\$00.69<sup>0</sup>



ZIP 72160  
011D10608725

Arkansas Dept. of Environmental Quality  
Water Division  
5301 Northshore Drive  
North Little Rock AR 72118-5317

