

NON-COMPLIANCE LETTER

DATE: June 26, 2015

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY
5301 NORTH SHORE DRIVE
NORTH LITTLE ROCK, AR 72118-5317
ATTN: ENFORCEMENT SECTION

RE: NPDES PERMIT NO: AR0034380

DISCHARGE NUMBER 001-A

CLIENT: STUTTGART, CITY OF
ADDRESS: P.O. BOX 130
CITY: STUTTGART
STATE: AR
ZIP: 72160
PHONE:
CONTACT: TOMMY LAWSON, MANAGER

DATE OF NON-COMPLIANCE	PARAMETER EXCEEDED	CONCENTRATION	LOADING	PERMIT LIMITS
05/01-31/15	* TRC INST MAX	<.050		.033
	** TSS MO AVG	15.167		15

WE FEEL THIS PROBLEM WAS DUE TO:

* LAB CHECKED CHLORINE AND FOUND DETECTION LIMIT TO BE <.02.

** Plant overloaded with sludge

WE PLAN ON CORRECTING THE PROBLEM IN THIS MANNER:


FIELD TECH WILL USE NEW DETECTION LIMIT.

** Processing as much sludge as possible during the day

TIME ESTIMATED THAT IT WILL TAKE:

We are hoping within a month TSS will be within permit limits.

YOURS TRULY,



AUTHORIZED SIGNATURE

STÜTTGART MUNICIPAL WATER WORKS

612 SOUTH COLLEGE - P.O. BOX 130
STÜTTGART, ARKANSAS 72160-0130

RETURN SERVICE REQUESTED

Hasler

06/30/2015

US POSTAGE

FIRST-CLASS MAIL

\$00.48⁰



ZIP 72160
011D10608725

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118-5317

72118531799

