

NON-COMPLIANCE LETTER

DATE: December 27, 2016

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY  
5301 NORTH SHORE DRIVE  
NORTH LITTLE ROCK, AR 72118-5317  
ATTN: ENFORCEMENT SECTION

RE: NPDES PERMIT NO: AR0034380

DISCHARGE NUMBER:001-A

CLIENT: STUTTGART, CITY OF  
ADDRESS:P.O. BOX 130  
CITY: STUTTGART  
STATE: AR  
ZIP: 72160  
PHONE:  
CONTACT: TOMMY LAWSON, MANAGER

DATE OF NON-COMPLIANCE	PARAMETER EXCEEDED	CONCENTRATION	LOADING	PERMIT LIMITS
11/01-30/16	TSS MO AVG	24.39		15
	TSS: 7 DA AVG	39.83		22.5
	F.C 30DA GEO	1137		1000
	F.C 7 DA GEO	5897		2000

WE FEEL THIS PROBLEM WAS DUE TO:

TSS-Pump station to filters has been down for upgrading  
FC - Vacuum regulators on SO2 cylinders failed

WE PLAN ON CORRECTING THE PROBLEM IN THIS MANNER:

TSS - Pump station upgrade  
FC - Vacuum regulator has been repaired

TIME ESTIMATED THAT IT WILL TAKE:

TSS - Within 1 month      FC - has been repaired

YOURS TRULY,

  
\_\_\_\_\_  
AUTHORIZED SIGNATURE

# STUTT GART MUNICIPAL WATER WORKS

612 SOUTH COLLEGE – P.O. BOX 130  
STUTT GART, ARKANSAS 72160-0130

RETURN SERVICE REQUESTED

Arkansas Department of Environmental Quality  
Enforcement Section  
5301 North Shore Drive  
North Little Rock, AR 72118-5317

Hasler

FIRST-CLASS MAIL

01/09/2017

**US POSTAGE \$000.46<sup>5</sup>**

721185317 R015

