

NON-COMPLIANCE LETTER

DATE: October 19, 2015

ARKANSAS DEPARTMENT OF ENVIRONMENTAL QUALITY  
5301 NORTH SHORE DRIVE  
NORTH LITTLE ROCK, AR 72118-5317  
ATTN: ENFORCEMENT SECTION

RE: NPDES PERMIT NO: AR0034380

DISCHARGE NUMBER:001-A

CLIENT: STUTTGART, CITY OF  
ADDRESS:P.O. BOX 130  
CITY: STUTTGART  
STATE: AR  
ZIP: 72160  
PHONE:  
CONTACT: TOMMY LAWSON, MANAGER

DATE OF NON-COMPLIANCE	PARAMETER EXCEEDED	CONCENTRATION	LOADING	PERMIT LIMITS
09/01-30/15	D.O INST MIN	5.61		6
	F.C 7 DA GEO	2210		2000

WE FEEL THIS PROBLEM WAS DUE TO:

D.O. Electrical problem in main control box

F.C. Chlorine injector line

WE PLAN ON CORRECTING THE PROBLEM IN THIS MANNER:


D.O. Electrical problem has been repaired by a certified electrician

F.L. Chlorine injector line has been repaired

TIME ESTIMATED THAT IT WILL TAKE:

2 hours or less

YOURS TRULY,

  
\_\_\_\_\_  
AUTHORIZED SIGNATURE

# STUTTGART MUNICIPAL WATER WORKS

612 SOUTH COLLEGE – P.O. BOX 130  
STUTTGART, ARKANSAS 72160-0130

RETURN SERVICE REQUESTED

Hasler

FIRST-CLASS MAIL

10/19/2015

**US POSTAGE** \$000.92<sup>5</sup>



ZIP 72160  
011E10672532

Arkansas Dept. of Environmental Quality  
ATTN: Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118-5317