

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City of Benton NPDES Permit No.: AR0036498 Monitoring Period (Month/Year): 03 / 19

No Sanitary Sewer Overflows This Monitoring Period

Cause(s) of SSO		Environmental Impact	Action(s) Taken		Ultimate Discharge Location
C - Construction	D - Debris	EFK - Evidence of Fish Kill	EC - Environmental Cleanup	JV - Jet Vac	GR - Ground
EF - Equipment Failure	C - Grease	OEHC - Evidence of Human Contact	HC - Hvdro Cleaned	SL - Spread Lime	CR - Creek / Stream / River (specify)
LF - Line Failure	R - Rainfall (I&1)	OEEI - Evidence of Environmental Impact	HR - Hand Rodded	DD - Disinfected and Deodorized	DI - Ditch
PF - Power Failure	RO - Roots		MR - Machine Rodded		DR - Drop Inlet
V - Vandalism		NEAH - No Evidence of Adverse Health or Environmental Impact	PN - Public Notification	GP - Used Generator to Power Equipment	PA - Paved Area
			EN - Referred to Engineering		CB - Contained in Building

Starting Location (Address, Intersection, or Manhole #)	Start Date of SSO	End Date of SSO	Estim. Volume (in gallons)	Cause(s) Of SSO	Environmental Impact	Action(s) Taken	Discharge Location
913 Grapevine	03/01/2019	03/01/2019	200 gallons	RO	NEAH	HC,DD, JV	GR
Overview L/S- 1312 Ridgecrest Dr.	03/05/2019	03/05/2019	250 gallons	EF,	NEAH	HC,DD, JV	GR
# 3 Summerwood Dr.	03/06/2019	03/06/2019	300 gallons	C,D	NEAH	JV,DD,HC,SL,PN	GR
917 Columbia	03/25/2019	03/25/2019	500 gallons	C, R	NEAH	JV,DD,HC	GR



 Signature of Cognizant or Ranking Official

 Date 04/17/2019

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Mail together with DMR submission NO LATER THAN THE 25th OF THE MONTH FOLLOWING THE MONITORING PERIOD to:
 ADEQ Office of Water Quality * 5301 Northshore Drive * North Little Rock, AR 72118