

ADEQ

A R K A N S A S
Department of Environmental Quality

April 1, 2011

City of Benton, WWTF
Attention: Jonathan Buff
616 West Hazel
Benton, AR 72015

RE: NPDES Permit Number AR0036498, AFIN 63-00063

Dear Mr. Buff:

A recent review of the NPDES file for the City of Benton's WWTF has revealed the following violations for the monitoring period ending **02/28/2011**.

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT	UNITS
001-B	DO	6.2	7.5 Mo Av Mn	Mg/L
001-B	TSS	1477.4	1038 Mo Av	lb/d
001-B	TSS	33.7	15 Mo Av	mg/L
001-B	TSS	102.5	22.5 7 Da Av	mg/L

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Please refer to NPDES Permit Number AR0036498 and AFIN 63-00063 in any written correspondence to ADEQ. Should you have any questions, feel free to contact me at 501-682-0631 or e-mail at meints@adeq.state.ar.us.

Sincerely,



René E. Meints
Enforcement Analyst
Water Division

