

ADEQ

ARKANSAS
Department of Environmental Quality

June 27, 2012

Terry McClennahan, Mgr.
BENTON WW TREATMENT PLANT
614 West Hazel
Benton, AR 72018

RE: NPDES Permit No. AR0036498, AFIN No. 63-00063

Dear Mr. McClennahan:

A recent review of the NPDES file for BENTON, City of has revealed the following violations for the monitoring period ending August 31, 2010:


<u>OUTFALL</u>	<u>PARAMETER</u>	<u>VIOLATION</u>	<u>LIMIT</u>	<u>UNITS</u>
001B	TSS	20.128	15	mg/L

Any violation of your NPDES Permit is subject to enforcement action by this Department pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Violations and non-compliance reports documenting corrective actions are maintained at the Department, and are used to determine possible future enforcement actions by the Department. **No DMR has been received for this violation per our records.**

If you have any questions on this matter, please contact me at the address below or at 501-682-0636 or you may e-mail me at stowe@adeq.state.ar.us.

Sincerely,



Billy Stowe
Enforcement Analyst
Water Division

ENFORCEMENT CODING SHEET

SCREEN ID ENACS

AR00036498 BENTON, City of

AFIN 63-00063

Enforcement action code **03 (warning letter)**

Enforcement action date **June 27, 2012**

Action issued by **State**

Enforcement Docket No.

Violation Type **E3 Specific effluent violatons**

=====

SCREEN ID EAKS

<u>DSDG</u>	<u>LTYP</u>	<u>PARM</u>	<u>MLOC</u>	<u>SEAN</u>	<u>MODN</u>	<u>MVDT</u>
001B	F	00530	1	0	0	7/31/2010