

Tiana Toups (adpce.ad)

From: Gregory Becker <gbecker@bentonutilities.com>
Sent: Tuesday, October 3, 2023 4:37 PM
To: Tiana Toups (adpce.ad)
Subject: SSO - Hwy 5/Saline River - Benton Utilities Wastewater Treatment Plant (AR0036498)

Hello Tiana,

Per your request:

Date Overflow Began:
9/26/2023
12:00 pm

Date Overflow Ended:
9/26/2023
6:00 pm

Facility Name:
Benton Utilities Wastewater Treatment Plant
Permit Number:
AR0036498

Type of Overflow:
Service Line Overflow (12" Force Main Rupture)

Cause:
Line Failure/Break

Volume of Overflow:
1,500 gallons

Action Taken:
Hydro Cleaned
Disinfected and Deodorized

Please let me know if you have any questions or need any additional information.

Thank you,

Gregory Becker
Wastewater Treatment
Benton Utilities
616 West Hazel
Benton, AR 72015
Phone: 501-776-5982
Cell: 479-459-8560
gbecker@bentonutilities.com

ATTENTION: This email and any files transmitted with it are intended solely for the use of the individual or entity to which they are addressed. Any unauthorized used, disclosure or distribution is prohibited. If you are not the intended recipient, please contact the sender by reply email and destroy all copies of the original message. The views or opinions presented in this email are solely those of the author and do not necessarily represent those of Benton Utilities. You are warned to check this email and any attachments for the presence of viruses. Benton Utilities accepts no liability for any damage caused by any virus transmitted by this email.