

Sanitary Sewer Overflow Monthly Report

Facility Name: City of Benton

Permit Number: AR0036498

Reporting Period (Month/Year): November 2015

No Sanitary Sewer Overflows This Monitoring Period

Cause(s) of SSO		Sanitary Sewer Code Description		SSO Impact	Adverse Health or Environmental Impact		Adverse(s) Action	Ultimate Discharge Location
CO-Construction	D-Debris	NEAR-NO Evidence of Adverse Health or Environmental Impact	OR-OC-Observed or Evidence of Human Contact	SSO Volume (in Gallons)	Estimated Volume (in Gallons)	Environmental Impact	Actions (w/ Timeline to Address SSO)	Ultimate Discharge Location
E-Equipment Failure MC-Hydris Clean	G-Ground L-F-Lug Failure/Break	OR-OC-Observed or Evidence of Human Contact EPC-Evidence of Fish Kill						CR-Creek/Stream/River (please specify)
E-Rainfall RO-Roots	MC-Roots & Obstruction V-Vandalism							Ditch DR-Drop Inlet
								CR-Ground Surface PA-Paved Area CB-Contained in Building
2613 Meadow Lane	K14-56	11/13/2015	11/13/2015	500	RG	NEAH	HC Jet-Vac disinf./dead.	GR
Caldwell left Sta.	M10-645	11/14/2015	11/14/2015	4,500	E, Power Failure	NEAH	HC Jet-Vac disinf./dead.	CR - McNeill Creek
1100 Bks of Brookview	M14-13	11/28/2015	11/28/2015	9,000	I + I - R	NEAH	NO, 2016 goal to pipe burst	CR - Depot Creek

Signature of City of Benton
Signature of Cognizant or Filing Official

12/23/2015

Date

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.