

Sanitary Sewer Overflow Monthly Report

Facility Name: Cty of Benton

Permit Number: AR0031498

Reporting Period (Month/Year): April 2015

No Sanitary Sewer Overflows This Monitoring Period

Cause(s) of SSO		SSO Impact		SSO Description		Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAR-None	Evidence of Adverse Health or Environmental Impact	WO-Work Order			CR-Creek/Stream/River (please specify)
E-Equipment Failure	G-Creosote	OERC-Observed or Evidence of Human Contact		EC-Environmental Cleanup			Ditch
EC-Hydro Clean	LE-Lint	ERK-Evidence of Fish Kill		HC-Hydro Cleaned			DR-Drop Inlet
R-Rainfall	RC-Roots & Obverse			HR-Hand Raked			CR-Ground Surface
RO-Roots	V-Vandalism			EN-Referred to Engineering			PA-Paved Area
				PN-Public Notification			CB-Contained in Building

Location	Milestone #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Discharge Location
1824 Chatfield	Lift Station	04/26/2015	04/26/2015	800	LF	NEAH	HC Disinfect Decomized Pump Truck Jet-Vac	DI

Signature of Cognizant or Ranking Official: Jonathan W. Bnyx

Date: 5/16/2015

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."