

Sanitary Sewer Overflow Monthly Report

Facility Name: City of Boston

Permit Number: AR0036498 Reporting Period (Month/Year): Sept. 2016

No Sanitary Sewer Overflows This Monitoring Period

Cause(s) of SSO		SSO Impact		SSO Description		Action(s) Taken		Ultimate Discharge Location	
CO-Construction	D-Debris	NEAR-No Evidence of Adverse Health or Environmental Impact	ORWC-Observed or Evidence of Human Contact	Course of SSO	Environmental Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location		
E-Equipment Failure EC-Hydris Clean	G-Ground LFL-Log Failure/Block		ORWC-Observed or Evidence of Human Contact EHC-Evidence of Fish Kill						
R-Rainfall RO-Roots	RC-Roots & Obstruction V-Vandalism								
Location	Manhole #	Start Date of SSO	End Date of SSO	Volume (in gallons)	Course of SSO	Environmental Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location	
North Shore Lift Sta. 3150 North Shore Dr.	Lift Station	09/02/2016	09/02/2016	400 gal.	E	NEAH	Reset breaker check electric disinfect/deodorize HC	GR	

Genot Law Bull

10/14/2016

Date

Signature of Cognizant or Ranking Official
 I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."