

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: Benton Utilities Wastewater Treatment Plant NPDES Permit No.: AR0036498 Monitoring Period (Month/Year): 09 / 23

No Sanitary Sewer Overflows This Monitoring Period

REPORT CODE DESCRIPTIONS			
Cause(s) of SSO	Environmental Impact	Action(s) Taken	Ultimate Discharge Location
C - Construction	EFK - Evidence of Fish Kill	EC - Environmental Cleanup	GR - Ground
EF - Equipment Failure	OEHC - Evidence of Human Contact	HC - Hydro Cleaned	CR - Creek / Stream / River (specify)
LF - Line Failure	OEEI - Evidence of Environmental Impact	HR - Hand Rodded	DI - Ditch
PF - Power Failure	NEAH - No Evidence of Adverse Health or Environmental Impact	MR - Machine Rodded	DR - Drop Inlet
V - Vandalism		PN - Public Notification	PA - Paved Area
		EN - Referred to Engineering	CB - Contained in Building

Starting Location (Address, Intersection, or Manhole #)	Start Date of SSO	End Date of SSO	Estim. Volume (in gallons)	Cause(s) of SSO	Environmental Impact	Action(s) Taken	Discharge Location
611 Brent Road, Benton, AR (Caldwell LS)	09/20/2023	09/20/2023	300	EF	NEAH	JV, HC, DD	CR (McNeil Creek)
3324 River Heights, Benton, AR (12" pipe)	09/26/2023	09/26/2023	1500	LF	NEAH	JV, HC, DD	unnamed tributary (creek) to
611 Brent Road, Benton, AR (Caldwell LS)	09/29/2023	09/29/2023	1250	EF	NEAH	JV, HC, DD	CR (McNeil Creek)

Signature of Signizant or Ranking Official _____ Date 10/06/2023

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Mail together with DMR submission **NO LATER THAN THE 25th OF THE MONTH FOLLOWING THE MONITORING PERIOD** to:
 ADEQ Office of Water Quality ❖ 5301 Northshore Drive ❖ North Little Rock, AR 72118