## Toups, Tiana

**Subject:** TDS Schedule of Compliance - Progress Report One (1) year - Permit Number:

AR0036498 AFIN: 63-00063

Attachments: AR0036498 Progress Report TDS.pdf

**From:** Gregory Becker [mailto:gbecker@bentonutilities.com]

**Sent:** Wednesday, July 13, 2022 10:49 AM

**To:** Water-Enforcement-Report

**Cc:** Angela Freeman

Subject: TDS Schedule of Compliance - Progress Report One (1) year - Permit Number: AR0036498 AFIN: 63-00063

Please find attached the progress report for TDS compliance for permit number: AR0036498 AFIN: 63-00063.

The attached document shows compliance with the final permit limit (17,034.64 lbs./day).

Please reach out to me if you have any questions or need any additional information.

Sincerely,

Gregory Becker
Wastewater Treatment
Benton Utilities
616 West Hazel
Benton, AR 72015
Phone: 501-776-5982

Phone: 501-776-5982 Cell: 479-459-8560

gbecker@bentonutilities.com

ATTENTION: This email and any files transmitted with it are intended solely for the use of the individual or entity to which they are addressed. Any unauthorized used, disclosure or distribution is prohibited. If you are not the intended recipient, please contact the sender by reply email and destroy all copies of the original message. The views or opinions presented in this email are solely those of the author and do not necessarily represent those of Benton Utilities. You are warned to check this email and any attachments for the presence of viruses. Benton Utilities accepts no liability for any damage caused by any virus transmitted by this email.

## Permit Number: AR0036498 AFIN: 63-00063

## **Total Dissolved Solids**

Date	lbs./day
4/6/2021	6,877.50
5/5/2021	6,595.77
6/14/2021	8,457.18
7/9/2021	5,010.51
8/3/2021	4,958.05
9/1/2021	4,296.77
10/4/2021	5,491.39
11/1/2021	6,054.59
12/2/2022	6,682.34
1/12/2022	8,121.83
2/1/2021	7,677.39
3/7/2022	7,648.61
4/4/2022	7,635.10
5/9/2022	8,170.53
6/1/2022	6,104.21
7/5/2022	6,328.39

Permit limit: 17,034.64 Mass (lbs./day) once/month