

Leslie Allen-Daniel,

RE: AR0038466 City of Hope Permit Report Request, Part I, Section B of the permit compliance with the final effluent limitations for the sub-lethal WET limits for *P. promelas* and *C. dubia*, Total Recoverable Copper, and Total Recoverable Mercury. We the City of Hope Arkansas WWTP have been in compliance of all of the above limitations for the year of 2022. We did fail our 1<sup>st</sup> Quarter *Pimephales Promelas*, Method 1000.0 and did retest and pass this limitation.

This is our 3<sup>rd</sup> progress report due for this permit 3 of 3. Thank you and please let me know if you need anything further or have any questions/concerns.

SCOTT ROSS  
HOPE WWLAB