

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0038466 Discharge Number: A-001

Facility: CITY OF HOPE BIOS D'ARC

Address: 3307 HWY 67 WEST

City: HOPE State: AR Zip: 71801

Contact: SCOTT ROSS Phone: 870-722-2549

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
2/7/2023	COPPER	0.0	22.5	12.2

**We feel this problem was due to:**

6000 Gallons of leachate being discharged from our Landfill tanker truck into our system on the date of this sample collection.

**We plan on correcting the problem in this manner:**

Limiting the amount of leachate discharged daily into our system.

**Time estimated that it will take to correct problem:**

We will meet with our Landfill Supervisor and make the necessary changes immediately to correct the problem.

Sincerely,

SCOTT ROSS

3/7/2023

Submitted By:

Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)