

# City of Hope

---

P. O. Box 667 • Hope, Arkansas 71802-0667 • (870) 777-6701 • Fax (870) 722-2579

January 4, 2017

Leslie Allen-Daniel  
Water Enforcement Division  
ADEQ  
5301 Northshore Drive  
North Little Rock AR 72118

RE: Permit # AR 00038466

Dear Ms. Allen-Daniel:

Our Hope Arkansas Bois D'arc WW Treatment Plant, Permit # AR0038466 is under construction with extensive repair and reconstruction taking place. On 1/3/2017 the contractor, J. S. Haren, drained one of the two holding tanks at our plant causing an excessive amount of water to flow to the single tank in operation. The solids level in this tank rose rapidly, causing approximately 1000 gallons of solids to discharge into our outfall creek. We made proper adjustments to stop the overflow, disinfected and deodorized the area and there is no evidence of adverse health/environmental impact. This overflow was reported by Scott Ross, Wastewater Plant Operator to Bobby Arney, Hope Wastewater Superintendent and to Leslie Allen-Daniel at Water Quality Enforcement. Bobby Arney also notified Red Smith at ADEQ and Catherine Cook-City Manager of the overflow as well.

We will also note this problem on our monthly DMR. Please call if you have any questions at all.

Sincerely,



Catherine Cook  
City Manager  
Hope AR

CITY OF HOPE

PO BOX 667

HOPE AR 71802-0667



02 1P

\$ 000.465

0001931656 JAN 05 2017

MAILED FROM ZIP CODE 71801

ADE Q  
Water Enforcement Division  
Leslie Allen-Daniel  
5301 Northshore Drive  
North Little Rock, AR

7211865317



72118