

ADEQ

ARKANSAS
Department of Environmental Quality

January 4, 2016

Catherine Cook
City Manager, City of Hope
P.O. Box 667
Hope, AR 71801

RE: NPDES Permit Number AR0038466, AFIN 29-00034
NPDES Permit Effluent Violations

Dear Ms. Cook,


The Department recently performed a file review of the above referenced permit. The review revealed the following effluent violations:

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	Violation Code	% Vio	Parameter Code
05/31/2015	001-A	Coliform, fecal general, 7 DA GEO, #/100mL	2000	4000	E90	100%	74055-1-0
04/30/2015	001-A	Nitrogen, ammonia total [as N], MO AVG, lb/d	100.1	187	E90	87%	00610-1-1
04/30/2015	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	10	19.8	E90	98%	00610-1-1
04/30/2015	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	15	96	E90	540%	00610-1-1
01/31/2015	001-A	Coliform, fecal general, 7 DA GEO, #/100mL	2000	4000	E90	100%	74055-1-0

Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit requires you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0630 or e-mail at allen-daniel@adeq.state.ar.us.

Sincerely,



Leslie Allen-Daniel
Enforcement Analyst
Water Division, Enforcement Branch