

SANITARY SEWER OVERFLOW MONTHLY REPORT

Facility Name: Jonesboro City Water & Light - E

Permit Number: 43401

Reporting Period (Month/Year) December 2021

NO Sanitary Sewer Overflows This Monitoring Period

Cause(s) of SSO		Environmental Damage	Actions Taken		Ultimate Discharge Location
I/I - Rainfall	EF - Equipment Failure	NEAH - No Evidence of Adverse Health or Environmental Impact	MR - Machine Rodded	HC - Hydro Cleaned	CR - Creek/Stream/River (please specify)
R - Roots	CO - Construction		JV - Jet-Vac	EC - Environmental Cleanup	DI - Ditch PA - Paved Area
G - Grease	PF - Power Failure	OEHC - Observed or Evidence of Human Contact	HR - Hand Rodded	PN - Public Notification	DR - Drop Inlet
D - Debris	LF - Line Failure/Break	OEEI - Observed or Evidence of Environmental Impact	DD - Disinfected/Deodorized	ER - Emergency Repairs	GR - Ground Surface
V - Vandalism	OC - Other Cause	EFK - Evidence of Fish Kill	LIME - Spread Lime on Affected Area		CB - Contained in Building

Location	Type of Overflow	SSO Began	SSO Ended	Estimated Volume (in gallons)	Cause of SSO	Environmental Damage	Action(s) Taken	Ultimate Discharge Location
4008 Cobblestone Circle	Main Line Overflow	12/27/2021 @ 10:15 AM	12/27/2021 @ 11:35 AM	20	CO	NEAH	ER LIME	GR


Signature of Cognizant or Ranking Official

1/12/2022
Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine imprisonment for knowing violations."